

JEFFERSON PARISH

DEPARTMENT OF PURCHASING

CYNTHIA LEE SHENG PARISH PRESIDENT RENNY SIMNO DIRECTOR

April 19, 2021

ADDENDUM # 1

Bid Number: 50-00133789 Bid Opening Date: April 22, 2021

Description of Bid: LABOR, MATERIALS, AND EQUIPMENT NEEDED TO REMOVE AND INSTALL A RADIATOR AND FAN ON GENERATOR NO. 2 AT THE JEFFERSON PARISH EMERGENCY OPERATIONS AND COMMUNICATIONS CENTER

Question & Answer:

Q1: In section 8.1, it is requested that that the successful bidder "supply and install (4) new Brass isolation valves on the supply and return valves." Brass Isolation Valves like this do not have necks available so the handle can move freely once insulated. Would the Parish prefer Stainless Steel Valves, or to change the out with the same valves as before?

A1: Replace brass isolation valves with stainless steel isolation valves.

Revision of Specifications - Revise Section 8.1 as follows:

Section 8.1 Installation of Water Circuit Engine Cooling Heat Exchanger:

(Remove in its entirety) Supply and install four (4) new brass isolation valves on each existing supply and return line.

(Replace with the following) Supply and install four (4) new <u>Stainless steel isolation valves</u> on each existing supply and return line.

Sincerely,

Melissa Ovalle

Melissa Ovalle Buyer II

Bidders must acknowledge all addenda on the bid form. Bidder acknowledges receipt of this addendum on the bid form by indicating the addendum number listed above. Failure to list each addenda number on the bid form will result in bid rejection.

This addendum is a part of the contract documents and modifies the original bidding documents and specifications. The contents of this addendum shall be included in the contract documents. Changes made by this addendum shall take precedence over the documents of earlier date.

GENERAL GOVERNMENT BLDG. – 200 DERBIGNY ST., SUITE 4400, GRETNA, LA 70053 OFFICE 504.364.2678